


# **Vent-Axia®**

## **WARMAIR AIR CURTAIN**

Please read all the instructions carefully  
before starting the installation



Model  
Warmair6

Stock Ref  
456345A

## **230 / 240V 50Hz**

*PLEASE LEAVE THESE INSTRUCTIONS WITH END USER*



These instructions describe the various technical details of your “Warmair” 990mm 6kW air –curtain and its use. The air-curtain has a fan and heater designed to mount above a doorway, or similar, in industrial or commercial situations.

## **Safety & Guidance Notes**

All wiring to be in accordance with the current I.E.E Regulations, or the appropriate standards of your country and **MUST** be installed by a suitably qualified person.

Ensure that the mains supply (Voltage, Frequency, and phase) complies with the rating label.

**DO NOT** use this appliance where the following are general or present:-

Excessive moisture, excessive dust or fibres, grease or oil laden air, corrosive or flammable atmospheres.

**DO NOT** use this appliance in bathrooms

**DO NOT** handle the appliance with wet hands

**DO NOT** cover or partially cover the appliance. The tangential fan **MUST** have free air flow at all times, i.e. do not mount close to cupboards, etc.

Children, the elderly and the infirm may not always be aware of the danger involved in using electrical appliances. Never allow this appliance to be used without supervision.

## **Mounting**

When mounted over a standard shop doorway the unit should be fitted as low as possible and not more than 2.3 meters from ground level. A single unit will provide reasonable coverage for a one metre doorway, and for wider doorways units can be mounted end to end.

The unit should be positioned so that the airflow is not obstructed by any part of the doorframe.




When “ceiling” mounted, the discharge grille must protrude through the false ceiling as shown. All the slots must be below the ceiling line. Provision must be made, in the void above the false ceiling, for an adequate supply of air to the inlet side of the unit (see diagram below and right).

## **Installation**

Carefully unpack the unit and remove the top cover fixing screws.

The heater may be mounted in three alternative ways:-

1. Direct to a suitable wall or bearer by four No.8 wood screws through the holes provided in the back of the unit casing. Keyhole slots are provided for the top two fixings.
2. Suspended by 20mm conduit through the holes provided in the top of the unit.
3. Suspended by chains through the holes provided in the top of the unit.



## **Electrical Connections**

**WARNING:** ALWAYS ISOLATE THE MAINS SUPPLY BEFORE INSTALLATION, SERVICING OR MAINTENANCE.

All Regulations and requirements **MUST** be strictly followed to prevent hazards to life and property both during and after installation and during any subsequent servicing and maintenance.

**This Appliance MUST be Earthed**

This unit is suitable for connection to a 230/240 volt 50Hz single phase ac supply.

The heater consumes 6kW at 240 volts when switched to the full heat position.

(See below for wiring diagrams)

The appliance should be connected to the supply via a circuit in which there is an all-pole switch. Test for correct operation and refit the cover.


## **Operation**

The right hand switch connects the mains supply to the fan motor (giving a cool airflow) and Energises the heat control switches.

### **Heat control (6kW Warmair)**

When the centre switch (marked with a single Black dot) is depressed the heat output is 2kW. When the left-hand switch (marked with Two black dots) is depressed the heat output is 4kW. When both switches are depressed The heat output is 6kW

6kW Warmair



## **Maintenance**

**WARNING:** ALWAYS ISOLATE THE MAINS SUPPLY BEFORE INSTALLATION, SERVICING OR MAINTENANCE.

To obtain the best results from your heater it is necessary to avoid the build up of dust and dirt within the unit and on the air inlet and discharge grilles. For this reason regular cleaning is necessary, paying particular attention to the removal of dirt build up on the rotor blades. A single drop of light oil should be applied to the motor bearing from time to time.

### **Protection (Thermal cut-out)**

The units are protected in the event of fan failure, or an obstruction of the free airflow, by thermal PTC self hold cut-outs. Having tripped, the PTC cut-out remains open, effectively switching off the heating elements, as long as mains power is available inside the appliance.

**To reset the PTC self-hold cut-out proceed as follows:-**

**DO NOT ADJUST BY HAND ANY COMPONENTS**

1. The cut-out is reset by switching OFF the mains power to the heater.
2. Allow the heater to cool for 20 minutes.
3. Restart, Switch ON the heater. If the cut-out trips again consult a qualified electrician.

## VENT-AXIA CONTACT NUMBERS UK NATIONAL SALES CENTRE

### Domestic & Commercial

Tele: 01293 530202  
Fax: 01293 565169

### Industrial

Tele: 01293 441570  
Fax: 01293 534898

## REPUBLIC OF IRELAND

Vent-Axia Ventilation Ltd.  
Tele: (01) 450 4133 Fax: (01) 450 4570

## UK NATIONAL TECHNICAL SUPPORT

### Domestic & Commercial

Tele: 01293 526062  
Fax: 01293 551188

### Industrial

Tele: 01293 455196  
Fax: 01293 455197

Internet site at: [www.vent-axia.com](http://www.vent-axia.com)

Email: [info@vent-axia.com](mailto:info@vent-axia.com)

## The Vent-Axia Guarantee

Applicable only to products installed and used in the United Kingdom. For details of the Guarantee outside of the United Kingdom contact your local supplier.

Vent-Axia guarantees this product for two years from the date of purchase against faulty material or workmanship. In the event of any part being found to be defective, the product will be repaired, or at the Company's discretion the product will be replaced without charge, provided that the product:

- 1). Has been installed and used in accordance with the instruction given with each unit.
- 2). The electricity supply complies with the rating label.
- 3). Has not been misused, neglected or damaged.
- 4). Has not been modified or repaired by any person not authorized to do so by Vent-Axia.

### If claiming under terms of guarantee

Please return the complete product, carriage paid to your original supplier or nearest vent-axia centre, by post or personal visit. Please ensure that it is adequately packed and accompanied by a letter clearly marked "Guarantee claim" stating the nature of the fault and providing evidence of date and source of purchase.

The guarantee is offered to you as an extra benefit, and does not affect your legal rights

As part of the policy of continuous product improvement  
Vent-Axia reserve the right to alter specifications without notice

**Vent-Axia**

Head Office:- Fleming Way, Crawley, West Sussex RH10 9YX  
Tel:- 01293 526062 Fax:-01293 551188